

Generator Lead Line Status

NERC's "Project 2010-07 Generator Requirements at the Transmission Interface" has done research and analysis before establishing a current subset of standards for revision to address these interconnection facilities. In the meantime, NERC developed an interim approach as a draft directive found at this link:

<http://www.nerc.com/files/GO%20TO%20Directive%2010.07.11.pdf>

The draft directive was not well-received by the industry and was ultimately cancelled/not issued. However, in an effort to address the issue, NERC has approved 4 standards associated with Project 2010-07 (FAC-001-1, FAC-003-3, PRC-004-2.1a, and PRC-0051.1b) and has filed all four with FERC for approval.

This potential filing would address 4 important standards, but it is understood that there are issues remaining from FERC direction in Order 693 that have yet to be addressed.